



A **PLAYCORE** Company

LUXURY SERIES – ALUMINUM ANGLE FRAME (5 ROW)

ITEM 1: 4 row x 19' portable bleacher having a seating capacity of 42 net seats, GT Grandstands Model No. LT-0419ADV-A

MANUFACTURER: GT Grandstands, Inc., 2810 Sydney Road, Plant City, FL 33566, Ph (866) 550-5511, Fax (813) 305-1419

DESIGN: The bleachers shall be designed to support, in addition to their own weight, a uniformly distributed live load of not less than 100 psf of gross horizontal projection of the bleachers. All seat and foot plank members shall be designed to accommodate 200 plf across a 6' span with a maximum deflection of 9/16". The bleachers shall be designed to resist, with or without a live load, a horizontal wind load of 30 psf of gross vertical projection. In addition to the live load, the bleachers shall be designed to resist the following sway forces: (1) 24 plf of seat plank in a direction parallel to the length of the seat, and (2) 10 plf of seat plank in a direction perpendicular to the length of the seat. Under these loads, stresses in aluminum members and connections shall not exceed those specified for Building Type Structures by the Aluminum Association.

CONSTRUCTION: The understructure, including crossbracing, shall be of a welded, aluminum angle (6061-T6 alloy, mill finish) construction. The understructure of each unit shall consist of frames spaced at 6' centers joined by crossbracing at adequate points to comply with the design loads.

DIMENSIONS: The rise per row shall be 14", seat height 17", and tread depth per row of 36". Overall depth of unit is 11'-0". Clear width of unit is 20'. Top row seat height is 4'-10"

GUARDRAILS: Guardrail system shall be at all sides and rear of bleacher at all locations more than 30" above grade. Railing shall consist of a series of vertical picket panels of mill finish aluminum (6063-T52 alloy). Individual panels shall be secured to rail posts by galvanized bolts. Top of railing shall be 42" above the center of any adjacent seat. The guardrail system shall have no opening larger than 4" at any location more than 30" above grade including the triangular region underneath the seat formed by the tread and rise. The guardrail system shall be capable of sustaining a horizontal load of 50 plf and a vertical load of 100 plf. In addition the guardrail system shall be designed for a 200 lb concentrated load applied to the top rail in any direction.

SEAT PLANKS: Seat planks shall be 2"x12" nominal, extruded 6063-T6 aluminum alloy with a clear anodized finish and end cap.

BACKREST: Backrest shall be a 7" contoured aluminum extrusion (6063-T6 alloy) with a clear anodized finish and end caps.

BACKREST STANCHION: Backrest stanchions shall be an aluminum extrusion (6063-T6 alloy) with an anodized finish.

SPECIFICATIONS (Cont'd)

Luxury Series – Aluminum Angle Frame

Page Two

TREAD PLANKS: Tread planks shall be of three 2"x10" nominal, and one 2"x8" nominal, extruded 6063-T6 aluminum alloy with a mill finish and end cap.

RISER PLANKS: Riser planks shall be 1"x6" extruded aluminum alloy with a clear anodized finish and shall be provided under each row.

ALUMINUM PLANK HARDWARE: Tie-down assemblies consisting of a four-way adjustable aluminum clip, with galvanized bolt with nut and washer shall be provided for each connection point at each support.

aisle: Bleacher shall have (1) 4'-0" wide aisle equipped with aisle handrails as required per code. Additional planking shall be provided to close the aisle in the horizontal and vertical planes. Also has an 18" sub-step.

WARRANTY: GT Grandstands warrants to the Buyer that its bleachers shall be free from defects in material and workmanship under normal use for a period of five (5) years provided they are installed per GT Grandstands installation instructions and that component parts supplied by GT Grandstands are used. GT Grandstands' obligation under this warranty shall be limited to repair and exchange of any such item, which may prove defective under normal use (vandalism and premeditated damage excluded) during such period. GT Grandstands will release the warranty documents to the buyer only after the Buyer has paid GT Grandstands in full the final contracted amount.

LT-0419ADV-A